

Tagesgänge des Schmutzwassers

KT	Wertepaare des Tagesgangs: Uhrzeit (Uhr) / Anteil vom Mittel (A)											
	Uhr	A	Uhr	A	Uhr	A	Uhr	A	Uhr	A	Uhr	A
(-)	(h)	(-)	(h)	(-)	(h)	(-)	(h)	(-)	(h)	(-)	(h)	(-)
1	00:00	0.00	03:00	0.10	04:00	0.60	05:00	1.60	06:00	1.90	07:00	1.30
	08:00	1.10	09:00	0.80	10:00	1.00	11:00	1.90	12:00	3.00	13:00	2.50
	14:00	1.60	15:00	0.80	16:00	0.70	17:00	1.30	18:00	1.80	19:00	1.50
	20:00	0.40	21:00	0.10	22:00	0.00						
2	00:00	0.00	02:00	0.10	03:00	0.20	04:00	0.40	05:00	1.10	06:00	1.40
	07:00	1.10	08:00	0.90	09:00	0.70	10:00	1.10	11:00	1.70	12:00	1.70
	13:00	1.90	14:00	1.80	15:00	1.40	17:00	1.60	19:00	1.30	20:00	0.90
	21:00	0.90	22:00	0.50	23:00	0.30						
3	00:00	0.20	03:00	0.30	04:00	0.60	05:00	0.90	06:00	1.10	07:00	1.30
	09:00	1.40	10:00	1.70	11:00	1.80	12:00	1.85	13:00	1.80	14:00	1.45
	15:00	1.20	16:00	1.10	19:00	1.20	20:00	1.00	21:00	0.70	22:00	0.30
	23:00	0.20										
4	00:00	0.40	01:00	0.30	03:00	0.50	04:00	0.70	05:00	0.90	06:00	1.00
	07:00	1.10	08:00	1.20	09:00	1.30	10:00	1.40	11:00	1.60	12:00	1.70
	13:00	1.60	14:00	1.40	15:00	1.30	16:00	1.20	17:00	1.10	18:00	1.20
	19:00	1.00	20:00	0.90	21:00	0.80	22:00	0.60	23:00	0.50		
5	00:00	0.60	01:00	0.50	02:00	0.60	03:00	0.70	04:00	0.90	05:00	1.00
	07:00	1.10	09:00	1.20	10:00	1.30	11:00	1.40	12:00	1.50	13:00	1.40
	14:00	1.30	15:00	1.10	18:00	1.00	19:00	0.90	21:00	0.80	23:00	0.70
10	00:00	0.00	06:00	1.85	19:00	0.00						